



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/01/2022
Received: 08/09/2022
Sampled By: Charles A Spear
Work Order: 2222050

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Monroe S/P
Project # : -
Sample Type : Grab

Sampling Location: Monroe E/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2222050-01	Sample Name: 18981321 -030 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/12/22 15:30
2222050-02	Sample Name: 18981321 - 031 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/12/22 15:30
2222050-03	Sample Name: 18981321 -032 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/12/22 15:30
2222050-04	Sample Name: 18981321 -033 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/12/22 15:30
2222050-05	Sample Name: 18981321 -034 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/12/22 15:30
2222050-06	Sample Name: 18981321 -035 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2222050-07	Sample Name: 18981321 -036 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2222050-08	Sample Name: 18981321 -037 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2222050-09	Sample Name: 18981321 -038 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/30/22 16:14
2222050-10	Sample Name: 18981321 -039 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/01/2022
Received: 08/09/2022
Sampled By: Charles A Spear
Work Order: 2222050

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/P
Project # : -
Sample Type : Grab

Sampling Location: Monroe E/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2222050-11	Sample Name: 18981321 -040 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-12	Sample Name: 18981321 -041 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/30/22 16:14
2222050-13	Sample Name: 18981321 -042 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-14	Sample Name: 18981321 -043 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-15	Sample Name: 18981321 -044 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-16	Sample Name: 18981321 -045 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-17	Sample Name: 18981321 -046 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-18	Sample Name: 18981321 -047 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	08/30/22 16:14
2222050-19	Sample Name: 18981321 -048 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/30/22 16:14
2222050-20	Sample Name: 18981321 -049 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/30/22 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/01/2022
Received: 08/09/2022
Sampled By: Charles A Spear
Work Order: 2222050

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Monroe S/P
Project # : -
Sample Type : Grab

Sampling Location: Monroe E/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2222050-21	Sample Name: 18981321 -050 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	08/30/22 16:14
2222050-22	Sample Name: 18981321 -051 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-23	Sample Name: 18981321 -052 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-24	Sample Name: 18981321 -053 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/30/22 16:14
2222050-25	Sample Name: 18981321 - 054 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/30/22 16:14
2222050-26	Sample Name: 18981321 - 055 CF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/30/22 16:14
2222050-27	Sample Name: 18981321 - 056 SF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	08/30/22 16:14
2222050-28	Sample Name: 18981321 - 057 KF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	08/30/22 16:14
2222050-29	Sample Name: 18981321 - 058 KF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	08/30/22 16:14
2222050-30	Sample Name: 18981321 - 059 KF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/30/22 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/01/2022
Received: 08/09/2022
Sampled By: Charles A Spear
Work Order: 2222050

C L I E N T Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/P
Project # : -
Sample Type : Grab

Sampling Location: Monroe E/S

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2222050-31	Sample Name: 18981321 - 060 KF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00 Sample Composition: Raw Single						
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/30/22 16:14
2222050-32	Sample Name: 18981321 - 061 DW 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00 Sample Composition: Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/30/22 16:14
2222050-33	Sample Name: 18981321 - 062 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00 Sample Composition: Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/30/22 16:14
2222050-34	Sample Name: 18981321 -063 BF 22A						Matrix: Drinking Water
	Sampled: 8/8/22 0:00 Sample Composition: Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	08/30/22 16:14

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director