



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/17/2022
Received: 08/09/2022
Sampled By: Charles Spear
Work Order: 2221005

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/D
Project # : -
Sample Type : Grab

Sampling Location: Monroe High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2221005-01	Sample Name: 18990043 -001 DW 22A Sampled: 8/8/22 9:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-02	Sample Name: 18990043 -002 DW 22A Sampled: 8/8/22 9:32 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-03	Sample Name: 18990043 -003 BF 22A Sampled: 8/8/22 9:35 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2221005-04	Sample Name: 18990043 -004 BF 22A Sampled: 8/8/22 9:36 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2221005-05	Sample Name: 18990043 -005 BF 22A Sampled: 8/8/22 9:40 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	08/12/22 15:30
2221005-06	Sample Name: 18990043 -006 BF 22A Sampled: 8/8/22 9:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	08/12/22 15:30
2221005-07	Sample Name: 18990043 -007 OF 22A Sampled: 8/8/22 9:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	37	ppb	4	15 ppb	08/12/22 15:30 MCLE
2221005-08	Sample Name: 18990043 -008 CF 22A Sampled: 8/8/22 9:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	08/12/22 15:30
2221005-09	Sample Name: 18990043 -009 BF 22A Sampled: 8/8/22 10:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	18	ppb	1	15 ppb	08/12/22 15:30 MCLE
2221005-10	Sample Name: 18990043 -010 BF 22A Sampled: 8/8/22 10:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	16	ppb	1	15 ppb	08/12/22 15:30 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/17/2022
Received: 08/09/2022
Sampled By: Charles Spear
Work Order: 2221005

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/D
Project # : -
Sample Type : Grab

Sampling Location: Monroe High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2221005-11	Sample Name: 18990043 -011 DW 22A Sampled: 8/8/22 10:10 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-12	Sample Name: 18990043 -012 SF 22A Sampled: 8/8/22 10:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	08/12/22 15:30
2221005-13	Sample Name: 18990043 -013 SF 22A Sampled: 8/8/22 10:23 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	52	ppb	10	15 ppb	08/12/22 15:30 MCLE
2221005-14	Sample Name: 18990043 -014 BF 22A Sampled: 8/8/22 10:23 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	08/12/22 15:30
2221005-15	Sample Name: 18990043 -015 BF 22A Sampled: 8/8/22 10:24 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	22	ppb	2	15 ppb	08/12/22 15:30 MCLE
2221005-16	Sample Name: 18990043 -016 KF 22A Sampled: 8/8/22 10:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	15	ppb	2	15 ppb	08/12/22 15:30 MCLE
2221005-17	Sample Name: 18990043 -017 KF 22A Sampled: 8/8/22 10:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-18	Sample Name: 18990043 -018 KF 22A Sampled: 8/8/22 10:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/12/22 15:30
2221005-19	Sample Name: 18990043 -019 KF 22A Sampled: 8/8/22 10:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	08/12/22 15:30
2221005-20	Sample Name: 18990043 -020 DW 22A Sampled: 8/8/22 10:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/12/22 15:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/17/2022
Received: 08/09/2022
Sampled By: Charles Spear
Work Order: 2221005

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/D
Project # : -
Sample Type : Grab

Sampling Location: Monroe High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2221005-21	Sample Name: 18990043 -021 BF 22A Sampled: 8/8/22 10:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2221005-22	Sample Name: 18990043 -022 BF 22A Sampled: 8/8/22 10:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-23	Sample Name: 18990043 -023 BF 22A Sampled: 8/8/22 10:31 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	16	ppb	1	15 ppb	08/12/22 15:30 MCLE
2221005-24	Sample Name: 18990043 -024 BF 22A Sampled: 8/8/22 10:31 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	08/12/22 15:30
2221005-25	Sample Name: 18990043 -025 BF 22A Sampled: 8/8/22 10:32 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	08/12/22 15:30
2221005-26	Sample Name: 18990043 -026 BF 22A Sampled: 8/8/22 10:32 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2221005-27	Sample Name: 18990043 -027 DW 22A Sampled: 8/8/22 10:33 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	08/12/22 15:30
2221005-28	Sample Name: 18990043 -028 DW 22A Sampled: 8/8/22 10:34 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	08/12/22 15:30
2221005-29	Sample Name: 18990043 -029 BF 22A Sampled: 8/8/22 10:35 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	13	ppb	1	15 ppb	08/12/22 15:30

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/17/2022
Received: 08/09/2022
Sampled By: Charles Spear
Work Order: 2221005

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Monroe S/D
Project # : -
Sample Type : Grab

Sampling Location: Monroe High School

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director